Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 295/D/SWA/NSA Dated: 08/07/2026

It is certified that an inspection team headed by ALKA SINGH — CHEMIST

(Name of Officers with designation) from KANPUR NAGAR NIGAM PHED

inspected the SETH ANANDRAM JAIPURIA SCHOOL, BARRA, KANPUR

(Name & Address of the school) on 30/6/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no 431/SWA/CHEM dated 07/7/2026 of PUBLIC HEALTH LABORATORY K.N.N. (PHED Lab) certified that the Seth Anandram Jaipuria School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till ONE YEAR

Signature with Seal: .....

Name : Dr. Amit Singh Gour

Designation : N.S.A.M. कानपुर

Name & Address of the Office / Department : .....

To Seth Anandram Jaipuria School
Barra, Kanpur
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Scanned with OKEN Scanner

KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY, KANPUR NAGAR NIGAM

Chemical water analysis report for the M/S SETH ANANDRAM JAIPURIA SCHOOL

Sample taken from — — — SUBMERCIBLE — BARRA, KANPUR

Date of sample Drawn	30/6/2026
Date of analysis	30/6/2026
Physical Character	TRANSPARENT / ODOURLESS
P. H. Value	8.47
Free Ammonia Parts per 1000000	NIL
Albuminoid Ammonia Part per 1000000	NIL
Oxygen absorbed from pot. Permagnate in three hours at 37° C	0.4
Chloride Part per 1000000	26.00
Nitrates Parts per 1000000	TRACES
Nitrates Parts per 1000000	TRACES
Total solid part per 100000	740.00
Fixed solid Parts per 1000000	610.00
Volatils solid Parts per 100000	130.00
Appearance on ignition	NO CHARRING
Total hardness Parts per 1000000	384.00
Permanent hardness Parts per1000000	312.00
Temporary hardness Parts per 1000000	72.00

Remarks : POTABLE'

K.N.N. PRESS

No. 431/SWA/2026 dated 07/7/2026

Copy forwarded for fovour or information to

1) M/S Seth Anandram Jaipuria School Barra, Kanpur

2) N.S.A. Kanpur Nagar Nigam कानपुर

Nagar Swasthya Adhikari
Nagar Nigam Kanpur

अलका सिंह
केमिस्ट

नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

Scanned with OKEN Scanner

D.No.: 431/SWA/CHEM 07/7/2026

KANPUR NAGAR NIGAM

PUBLIC HEALTH LABORATORY NAGAR NIGAM KANPUR

Result of Bacteriological Examination of Water Sample taken from SETH ANANDRAM JAIPURIA SCHOOL, BARRA, KANPUR

Name & designation of the person collecting samples. ALKA SINGH — CHEMIST

Date & time of *collection*	Source of sample	Colony count on Agar Agar per M. L. of water		Presumptive Coliform count				Probable on of coliform organism in 100 CC of original water	Free Residual Chiorine part per Million	REMARKS
		at 37.c in 48 hours	at room temp-raturn in 72 hours	Quantity of water put in each tube No of tubes put up	50Ml. 1	10 Ml. 5	1 Ml 5			
30/6/2026	SUBMERCIBLE	'22'	'61'	—	—	'2'	'1'	Zero	NIL	Satisfactory.

Remarks. Chlorination is very necessary / R.C. must be 0.2 ppm

Copy for Information Forwarded to (1) w/s Seth Anandram Jaipuria School

(2) N.S.A Kanpur Nagar Nigam

Nagar Swadthya Adhikari
नगर स्वास्थ्य अधिकारी
नगर निगम कानपुर

अलका सिंह
केमिस्ट
नगर निगम कानपुर

Scanned with OKEN Scanner